

ADDENDUM NO. 3

City of Chattanooga
Eastgate Family Justice Center
Derthick Henley & Wilkerson Architects

Date: 23 Sep 2015

File: 2142

The following amendments to the specifications and/or revisions to the drawings shall be a part of the contract documents. Bidders, therefore, shall consider them when preparing cost estimates, and the contractors shall be bound by them.

SPECIFICATIONS

City of Chattanooga, Front End Specifications

Section 00 11 16 Invitation to Bid


Change the date and time of opening bids to **2:00 p.m. EDT on Tuesday, October 13, 2015.**

DRAWINGS

Sheet A-402 Interior Elevations

Elevation E18 / A-402 (8 ½" x 11") Issued as part of this addendum.

The open knee space at Client Kitchen A-106 is enlarged to provide adequate access and clearance per ANSI 117.1-2009.



NOTE:
 OPEN KNEE SPACE INDICATED IN ELEVATION COMPLIES WITH ANSI 117.1 - 2009 902.4 WITH COUNTERTOP HEIGHT AT 34".
 TOE CLEARANCE AND KNEE CLEARANCE COMPLIES WITH ANSI 117 - 2009 606.2 AND WITH CLEAR FLOOR SPACE COMPLYING WITH 305.3.