

**ADDENDUM THREE  
HCSO-CPD TRAINING TRAILER RELOCATION  
CONTRACT NO. P-15-001-201  
CITY OF CHATTANOOGA, TENNESSEE**

The following changes shall be made to the Contract Documents, Specifications, and Drawings:

**I. Q&A**

Q: Will a metal roof be accepted as a replacement for the existing trailer roof?

A: No. The Contractor shall bid removal of existing EPDM roof and underlayment and replace with materials as specified in the Specifications and Plans.

April 26, 2016

\_\_\_\_\_  
/s/ Justin C. Holland, Administrator  
City of Chattanooga  
Department of Public Works